

Fresh Air Override Unit

0 / 25 / AUTO / 75 / 100% Ventilation
Output 0 -10v dc

Temperature Override Unit

-2 / -1 / AUTO / +1 / +2°C
Output 0 -10v dc

Manual Positioner

Range 0 - 100%
Output 0 - 10v dc

Rotary Override Switch

Auto / Close / Open
Summer / Winter
etc.

High CO₂ Level Indicator



September 2012

Blue River Controls Limited

Unit 4A, Marsh Hill Farm, Marsh, Aylesbury, Bucks HP17 8ST
Tel: 01296 613110 Email: sales@bluerivercontrols.co.uk